

# YECSIM Model in GRA

Yukon Utilities Board

February 12, 2018



**YUKON  
ENERGY**

# Overview of Presentation

1. Context for YECSIM in 2017/18 GRA
2. Fundamentals of YECSIM – User Manual
3. Application of YECSIM in 2017/18 GRA

# Context for YECSIM in 2017/18 GRA


# Context for YECSIM in 2017/18 GRA

- ✓ YECSIM results used for :
  - GRA thermal forecast for test years
  - DCF year end determinations (for rate stabilization purposes)
  - Business case based on LTA Hydro
- ✓ As this is GRA focused discussion – comments are focused on #1 and #2 above

# Context for YECSIM in 2017/18 GRA

## Water-Related & Thermal Generation Forecasts


- ✓ A GRA requires a **thermal generation forecast**
- ✓ The **thermal generation forecast** depends on the **hydro generation forecast**, which is affected by forecast water



# Context for YECSIM in 2017/18 GRA


## Water-Related & Thermal Generation Forecasts

- ✓ Change in water from GRA forecast is a ratepayer risk
- ✓ Need to assess at the end of each fiscal year
- ✓ Determines YEC's thermal costs for its accounts



# Context for YECSIM in 2017/18 GRA

## Water-Related & Thermal Generation Forecasts



# Context for YECSIM in 2017/18 GRA

## Generation Forecast Methods Can Vary

- ✓ *Forecast methods can vary*
- ✓ *Regardless of forecast used, need consistent implementation in GRA and for determining diesel generation costs at each year end*

### Short Term Forecast


- *Looks at actual water available*
- *Greater rate instability*

### Long Term Average Forecast

- *Expected hydro/ thermal over range of conditions*
- *Promotes rate stability/ intergenerational equity*



# History Leading to YECSIM in 2017/18 GRA



# Conclusion re: YECSIM in 2017/18 GRA

## ✓ LTA in GRA forecast

- Since mid 90's, LTA is accepted as determinative for YEC thermal requirements
- In 2012/13, YUB approved LTA as determined by YECSIM model

## ✓ LTA thermal generation for accounting at each year end

- Based on actual load, YECSIM results determines difference in thermal generation which leads to actual fuel expense and transfer to/from DCF
- The DCF is the ratepayer stabilization mechanism

# Fundamentals of YECSIM

# Fundamentals of YECSIM

- Model overview
- User Manual structure
- Methodology
- Inputs
- Outputs

# Fundamentals of YECSIM

## Model overview

Appendix 2.4 of December 6/17 Two-Part ERA Application

- ✓ **Simulation model that estimates hydro and thermal generation**
  - Determines LTA hydro and thermal generation (GRA role)
  - Developed by the KGS Group in 2008
  
- ✓ **Scenario based model**
  - Range of recorded water inflows and future load
  
- ✓ **Rule based model**
  - Water-related license conditions
  - Plan specific constraints (e.g. Mayo Lake outlet restriction, downstream icing)
  - Rules to maximize use of water, minimize use of thermal
  
- ✓ **User Manual**
  - Provided to facilitate testing of YECSIM by interveners and the Board

# Fundamentals of YECSIM

- Model overview
- User Manual structure
- Methodology
- Inputs
- Outputs

# Fundamentals of YECSIM

## User Manual Structure

### Key Sections of Manual for understanding YECSIM:

#### Key Sections of Manual

##### 1.0 Introduction

- ✓ Overview of model

##### 4.0 Input

- ✓ Review of model inputs

##### 5.0 Output

- ✓ Review of model outputs

##### 6.0 Program Theory

- ✓ Section 6.1 review of modelling strategy & assumptions

#### Appendices [model input details]

**Appendix A:** Format of Input Files

**Appendix B:** Reservoir Rule Curves

**Appendix C:** Program Flowcharts

**Appendix D:** Tables of Input Parameters

**Appendix E:** Licenses for YEC Reservoirs & Plants

**Note:** Remaining sections of the User Manual are mainly for operators, e.g., sections 2 and 3 on installing and working with YECSIM graphical interface, section 7 on earlier example simulations, and section 8 tips on program application and problem avoidance

# Fundamentals of YECSIM

## User Manual Status

### ✓ **User Manual Status:**

- Developed in 2009, updated in 2017
- LTA wind is removed from load used for YECSIM simulation
- YECSIM does not separate diesel vs. LNG thermal



# Fundamentals of YECSIM

- Model overview
- User Manual structure
- Methodology
- Inputs
- Outputs

# Fundamentals of YECSIM

## Methodology

User Manual sections 1 and 6.1.1 to 6.1.5

- ✓ Address single load scenario for one load year – weekly time steps
  - Total annual demand distributed by week over entire year.
  - Weekly time steps chosen to balance various factors (p106).
- ✓ Creates combinations of historical inflows over repeated load (load years (User Manual 8 load years being)
  - Water years - historic lake inflows
  - Cycle - a combination of water years over load years
  - The number of cycles equals the number of water years.
- ✓ Calculates average over all of the cycles

# Fundamentals of YECSIM Methodology

	Load	Load	Load	Load	Load	Load	Load	Load
Sequence 1	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8

OUTPUT	Average	Average	Average	Average	Average	Average	Average	Average
--------	---------	---------	---------	---------	---------	---------	---------	---------

# Fundamentals of YECSIM Methodology

	Load	Load	Load	Load	Load	Load	Load	Load	Load
Sequence 1	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8	
Sequence 2		Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8

OUTPUT	Average	Average	Average	Average	Average	Average	Average	Average
--------	---------	---------	---------	---------	---------	---------	---------	---------

# Fundamentals of YECSIM

## Methodology

	Load	Load	Load	Load	Load	Load	Load	Load
Sequence 1	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8
Sequence 2	Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7

OUTPUT	Average	Average	Average	Average	Average	Average	Average	Average
--------	---------	---------	---------	---------	---------	---------	---------	---------

# Fundamentals of YECSIM Methodology

	Load	Load	Load	Load	Load	Load	Load	Load	Load
Sequence 1	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8	
Sequence 2	Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	
Sequence 3		Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7

OUTPUT	Average	Average	Average	Average	Average	Average	Average	Average
--------	---------	---------	---------	---------	---------	---------	---------	---------

# Fundamentals of YECSIM Methodology

	Load	Load	Load	Load	Load	Load	Load	Load
Sequence 1	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8
Sequence 2	Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7
Sequence 3	Inflow 7	Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6

OUTPUT	Average	Average	Average	Average	Average	Average	Average	Average
--------	---------	---------	---------	---------	---------	---------	---------	---------

# Fundamentals of YECSIM

## Methodology

	Load	Load	Load	Load	Load	Load	Load	Load
<b>Sequence 1</b>	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8
<b>Sequence 2</b>	Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7
<b>Sequence 3</b>	Inflow 7	Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6
<b>Sequence 4</b>	Inflow 6	Inflow 7	Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4	Inflow 5
<b>Sequence 5</b>	Inflow 5	Inflow 6	Inflow 7	Inflow 8	Inflow 1	Inflow 2	Inflow 3	Inflow 4
<b>Sequence 6</b>	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8	Inflow 1	Inflow 2	Inflow 3
<b>Sequence 7</b>	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8	Inflow 1	Inflow 2
<b>Sequence 8</b>	Inflow 2	Inflow 3	Inflow 4	Inflow 5	Inflow 6	Inflow 7	Inflow 8	Inflow 1
<b>OUTPUT</b>	Average	Average	Average	Average	Average	Average	Average	Average



# Fundamentals of YECSIM

## Methodology

	Load Year 1	Load Year 2	Load Year 3	Load Year 4	Load Year 5	Load Year 6	Load Year 7	Load Year 8
Cycle 1	Water Year 1	Water Year 2	Water Year 3	Water Year 4	Water Year 5	Water Year 6	Water Year 7	Water Year 8
Cycle 2	Water Year 8	Water Year 1	Water Year 2	Water Year 3	Water Year 4	Water Year 5	Water Year 6	Water Year 7
Cycle 3	Water Year 7	Water Year 8	Water Year 1	Water Year 2	Water Year 3	Water Year 4	Water Year 5	Water Year 6
Cycle 4	Water Year 6	Water Year 7	Water Year 8	Water Year 1	Water Year 2	Water Year 3	Water Year 4	Water Year 5
Cycle 5	Water Year 5	Water Year 6	Water Year 7	Water Year 8	Water Year 1	Water Year 2	Water Year 3	Water Year 4
Cycle 6	Water Year 4	Water Year 5	Water Year 6	Water Year 7	Water Year 8	Water Year 1	Water Year 2	Water Year 3
Cycle 7	Water Year 3	Water Year 4	Water Year 5	Water Year 6	Water Year 7	Water Year 8	Water Year 1	Water Year 2
Cycle 8	Water Year 2	Water Year 3	Water Year 4	Water Year 5	Water Year 6	Water Year 7	Water Year 8	Water Year 1
<b>LTA = Average of Yr 6 &amp; Yr 7</b>	Average LY1	Average LY2	Average LY3	Average LY4	Average LY5	Average LY6	Average LY7	Average LY8

# Fundamentals of YECSIM

- Model overview
- User Manual structure
- Methodology
- Inputs
- Outputs

# Fundamentals of YECSIM Inputs

User Manual sections 4, 6.1 and Appendices

## Section 4

- Overview of 18 data types under 3 headings:
  - ✓ For Lakes
  - ✓ For Generating Stations
  - ✓ For Load Forecast

## Section 6 & Appendices

- Section 6.1.3 – Inflows-Available-for Outflow (IAO)
- Sections 6.1.6 to 6.1.16 review various specific inputs
  - ✓ **Appendix D** – Tables of Input Parameters
  - ✓ **Reservoir Rule Curves & Stacking** – Section 6.1.11 and 6.1.14 and Appendix B [excerpt from textbook]
  - ✓ **License Limitations for Reservoirs and Plants** – Section 6.1.16 and Appendix E [copy of each current YEC Water License]

# Fundamentals of YECSIM Inputs

## Example of Marsh Lake

Edit Input Parameters for Lakes/Reservoirs

Marsh Lake | Aishihik Lake | Mayo Lake | Schwatka Lake | Canyon Lake | Wareham Lake

CONTENT: IAO DATA OF MARSH LAKE

**Elevation-Storage Coefficients**

Coefficient - 1: 652  
Coefficient - 2: 6.48E-06  
Coefficient - 3: 1

**Water Levels**

Minimum Level: 653.796 m  
Maximum Level: 656.234 m  
Initial Level: 656.234 m

**Import New Input Data**

IAO Data  
 Riparian Flows  
 Spillway Curve (All Gates Open)  
 Spillway Curve (10 Gates Open)  
 Lake Operation Levels Required by the Water Licence

**Lake Operation Condition**

Limit the change in flow from Marsh Lake to +- 20 m<sup>3</sup>/s in spring  
(Spring: from Week 12 to Week 19 (Note: Maximum Week 19))

No	Site No	Year No	Water Year	Week	Flow Rate (cms)
▶ 1821	2	1	1981	1	125.5
1822	2	1	1981	2	106.04
1823	2	1	1981	3	115.37
1824	2	1	1981	4	91.83
1825	2	1	1981	5	86.09
1826	2	1	1981	6	79
1827	2	1	1981	7	90.77
1828	2	1	1981	8	89.09
1829	2	1	1981	9	73.59
1830	2	1	1981	10	77.86
1831	2	1	1981	11	64.07
1832	2	1	1981	12	56.74
1833	2	1	1981	13	50.24
1834	2	1	1981	14	33.65
1835	2	1	1981	15	34.47
1836	2	1	1981	16	45.76
1837	2	1	1981	17	41.71
1838	2	1	1981	18	77
1839	2	1	1981	19	149.59

Add/Save | List | Goto G.S. | Return

# Fundamentals of YECSIM

## Major Inputs for 2017/18 GRA

### Water Record

- ✓ Historic inflows 35 years from 1981 to 2015
  - ✓ Goal is to include variety of water conditions
    - Floods, droughts, average
- 

### System Capability

- ✓ Generating station capacity & performance data
  - ✓ Generation dispatch order [maximize use of water; minimize diesel]
  - ✓ Licenced operating conditions
- 

### Load Forecast

- ✓ Load Forecast per GRA for 2017 and 2018

# Fundamentals of YECSIM


- Model overview
- User manual structure
- Methodology
- Inputs
- Outputs

# Fundamentals of YECSIM

## Major Outputs

User Manual Section 5.1 and 5.2

- ✓ Wide range of potential outputs identified in section 5.2





# Fundamentals of YECSIM

## Major Outputs – 2017/18 GRA

### **2017/18 GRA Simulations**

- ✓ User Manual has earlier number of load years (8) for simulations
  - Reviews how LTA based in initial YECSIM runs on 2 load years (yrs 6-7)
- ✓ YECSIM simulations use 20 load years for analysis
  - The first 6 load year simulations [years 1-6] & last load year simulation [Year 20] are removed from the averaging for LTAs
- ✓ 2017/18 GRA uses 35 water years
  - Each cycle begins with the next consecutive water year, e.g., Cycle 1: 1981-2000; Cycle 2: 1982 – 2001; Cycle 3: 1983-2002
  - Each cycle includes 20 load years (total of 700 simulations)
  - LTA calculated for 13 load years (year 7-19) in each of the 35 cycles



# Fundamentals of YECSIM

## LTA Calculation – 2017/18 GRA for each test year load forecast

### 35 Cycles

- 1
- 2
- 3
- 4
- 5
- .
- .
- .
- .
- .
- 34
- 35

### Water Years [1981-2015]

- 1981
- 1982
- 1983
- 1984
- 1985
- .
- .
- .
- .
- .
- 2014
- 2015

### "Load Years" used to calculate LTA by week

#### Cycles

*20 water years included in "load year" each cycle  
[700 separate simulations]*

- 1      **20 Years [1981, 1982.....1999, 2000]**
- 2      **20 Years [1982, 1983.....2000, 2001]**
- 3      **20 Years [1983, 1984.....2001, 2002]**
- 4      **20 Years [1984, 1985.....2002, 2003]**
- 5      **20 Years [1985, 1986.....2003, 2004]**
- .
- .
- *LTA calculation removes Load Years 1-6 and Year 20*
- .
- *Load Years 7-19 used to calculate LTA*
- .
- *35 Cycles x 13 Load Years = 455 simulations used to calculate LTA*
- .
- .
- 34      **20 Years [2014, 2015.....1997, 1998]**
- 35      **20 Years [2015, 1981.....1998, 1999]**

# Application of YECSIM in 2017/18 GRA

# Application of YECSIM in 2017/18 GRA

## Updates to YECSIM [Appendix 3.4 of GRA]

- ✓ Updated Assumptions on YECSIM for this GRA included in Appendix 3.4 of GRA [see App 3.4, section 1.2]:

### Additional Water Year Records

- 2012/13 GRA used 28 water years [1981-2008]
- 2017/18 GRA uses 35 water years [1981-2015]

### Recent Major System Changes

- CSTP, Mayo B
- Aishihik 3<sup>rd</sup> Turbine

### Changes re: Constraints

- Mayo Lake Outlet Channel constraints
- Mayo GS winter outflows due to downstream icing issues

# Application of YECSIM in 2017/18 GRA

- ✓ **2017/18 GRA Forecast** uses LTA hydro & thermal generation forecast as determined by YECSIM:
  - Table 3.4-1 is based on YECSIM model simulation
  - GRA load applied to this table results in forecast thermal generation.
  - This generation results in forecast fuel expense for revenue requirement.

# Application of YEC SIM in 2017/18 GRA

## Proposed DCF Table for 2017/18 GRA [Table 3.4-1]

Line Number	YEC Grid Load Net of Wind (GWh)	YEC Hydro Generation (GWh)	YEC Thermal Generation (GWh)	Increase in		
				Load (GWh)	Thermal Generation (GWh)	Thermal as % of Increased Load
	Column A	Column B	Column C	Column D	Column E	Column F = E/D
1	370.0	369.337	0.663			
2	375.0	373.626	1.374	5.0	0.710	14%
3	380.0	377.800	2.200	5.0	0.826	17%
4	385.0	381.845	3.155	5.0	0.955	19%
5	390.0	385.750	4.250	5.0	1.096	22%
6	395.0	389.503	5.497	5.0	1.246	25%
7	400.0	393.098	6.902	5.0	1.405	28%
8	405.0	396.528	8.472	5.0	1.570	31%
9	410.0	399.789	10.211	5.0	1.739	35%
10	415.0	402.877	12.123	5.0	1.911	38%
11	420.0	405.793	14.207	5.0	2.084	42%
12	425.0	408.537	16.463	5.0	2.256	45%
13	430.0	411.111	18.889	5.0	2.426	49%
14	435.0	413.521	21.479	5.0	2.590	52%
15	440.0	415.772	24.228	5.0	2.748	55%
16	445.0	417.874	27.126	5.0	2.898	58%
17	450.0	419.836	30.164	5.0	3.038	61%
18	455.0	421.669	33.331	5.0	3.167	63%
19	460.0	423.388	36.612	5.0	3.281	66%
20	465.0	425.007	39.993	5.0	3.380	68%
21	470.0	426.545	43.455	5.0	3.462	69%
22	475.0	428.019	46.981	5.0	3.525	71%
23	480.0	429.452	50.548	5.0	3.567	71%
24	485.0	430.865	54.135	5.0	3.587	72%

# Application of YECSIM in 2017/18 GRA

## Proposed DCF Table for 2017/18 GRA [Table 3.4-1]

**Table 3.4-1 steps** to determine LTA thermal generation for a given load [e.g., 417 GWh]:

- ✓ **Step 1:** Find the closest load in Column A that is less than given load (i.e., 415 GWh)
- ✓ **Step 2:** Find the thermal generation from Column C = 12.123 GWh
- ✓ **Step 3:** Difference between given load (417 GWh) and load from Step 1 (415 GWh) = 2 GWh
- ✓ **Step 4:** Apply % from Column F to difference from Step 3 = 0.841 GWh
- ✓ **Step 5:** Add Step 2 (12.123 GWh) and Step 4 (0.841 GWh) = 12.963 GWh

Expected thermal generation at 417 GWh load is 12.963 GWh

# Application of YECSIM in 2017/18 GRA DCF Determinations [Table 3.4.1]

## Table 3.4-1 Used During & After GRA Process

- ✓ Based on YECSIM model runs
- ✓ Provides LTA hydro & thermal for range of grid loads for Board approval

### GRA Filing Test Year Forecasts

- *Tab 2, Table 2-2*
- *Provides thermal generation requirement for forecast generation load for each test year*

### DCF Filing Final Assessments After GRA

- *Annual DCF Filing*
- *Used to determine expected thermal generation for actual grid load at each year end*
- *YECSIM model not re-run for DCF determinations*