

	2005		2004		2003		2002	
	Unit Available (%)	Unit Outage (hr)	Unit Available (%)	Unit Outage (hr)	Unit Available (%)	Unit Outage (hr)	Unit Available (%)	Unit Outage (hr)
WH1	77.01	2013.92	96.44	312.71	93.57	563.27	94.83	452.89
WH2	91.24	767.38	73.61	2318.10	96.93	268.93	92.53	654.37
WH3	93.33	584.29	92.57	652.65	69.74	2650.78	93.26	590.42
WH4	88.71	989.00	90.65	821.30	97.28	238.27	88.86	975.86
AH1	98.06	169.94	96.55	303.05	67.20	2873.28	98.08	168.19
AH2	94.00	525.60	96.65	294.26	99.34	57.82	90.48	833.95
WD1	99.85	13.14	99.86	12.30	70.39	2593.84	99.34	57.82
WD2	99.89	9.64	99.67	28.99	86.56	1177.34	77.65	1957.86
WD3	99.81	16.64	97.39	229.26	100.00	0.00	96.67	291.71
WD4	34.63	5726.41	99.56	38.65	98.90	96.36	87.73	1074.85
WD5	20.51	6963.32	84.10	1396.66	75.19	2173.36	85.55	1265.82
WD6	99.69	27.16	99.73	23.72	87.33	1109.89	86.40	1191.36
WD7	99.69	27.16	99.94	5.27	100.00	0.00	86.36	1194.86
FD2	99.16	73.58	97.31	236.29	100.00	0.00	100.00	0.00
FD3								
FD4	100.00	0.00	95.66	381.23	98.90	96.36	94.49	482.68
FD5	99.84	14.02	99.61	34.26	100.00	0.00	99.86	12.26
FD7								

	2001		2000		1999	
	Unit Available (%)	Unit Outage (hr)	Unit Available (%)	Unit Outage (hr)	Unit Available (%)	Unit Outage (hr)
WH1	86.70	1165.08	94.43	487.93	86.31	1199.24
WH2	88.11	1041.56	74.85	2203.14	93.41	577.28
WH3	94.84	452.02	92.73	636.85	87.95	1055.58
WH4	87.76	1072.22	94.60	473.04	91.06	783.14
AH1	91.61	734.96	86.01	1225.52	93.08	606.19
AH2	93.70	551.88	97.70	201.48	87.21	1120.40
WD1	98.79	106.00	91.87	712.19	85.94	1231.66
WD2	99.05	83.22	99.13	76.21	80.21	1733.60
WD3	81.84	1590.82	70.07	2621.87	97.44	224.26
WD4	26.63	6427.21	94.32	497.57	99.50	43.80
WD5	98.86	99.86	96.43	312.73	52.09	4196.92
WD6	93.55	565.02	85.71	1251.80	98.98	89.35
WD7	100.00	0.00	95.74	373.18	59.51	3546.92
FD2	retired	120.01	68.49	2760.28	99.95	4.38
FD3			99.57	37.67	98.36	143.66
FD4	retired		68.49	2760.28	99.97	2.63
FD5		219.00	93.06	607.94	41.18	5152.63
FD7		12.26	89.52	918.05	97.34	233.02

Note: Unit outage (hr) is the number of hours in a year where the unit is unavailable to generate power, without distinction as to Forced Outages and planned outages.